

# **CLEAR-DIVISIONS VARIOFOLD**

#### Introduction:

The following three (3) part specification offers the Standard and *Optional* features for the CLEAR-DIVISIONS VARIOFOLD moveable glass wall system. The yellow highlighted areas in the specification indicate an *Optional* selection that is available based on your project requirements.

In order to assist you with the design criteria KWIK-WALL has provided a Product Guide for the VARIOFOLD moveable glass wall system.

The Product Guide indicates the stack arrangements, perimeter trim and seals, final closures available, and also establishes the maximum partition height and width.

| VARIOFOLD Product Selection Guide |                                  |                       |   |                                |   |                            |                         |
|-----------------------------------|----------------------------------|-----------------------|---|--------------------------------|---|----------------------------|-------------------------|
| Model                             | Operation                        | Stack<br>Arrangements | Glass   | Perimeter<br>Trim and<br>Seals | Final<br>Closure<br>Options   | Maximum<br>Panel<br>Height | Maximum<br>Wall Width   |
| VARIOFOLD                         | Continuously<br>Hinged<br>Panels | Offset Stack          | Standard: Clear Optional: Etched, Decorated, Patterned or Berman editions | Trimless                       | Standard: Fixed Pivot Panel with Handle Optional: Fixed Swing Panel with Handle | 8'-6 3/4"<br>(2.61 m)      | **17'-8 1/2"<br>(5.4 m) |

<sup>\*\*</sup> Maximum Single Wall Width 17'-8 1/2" (5.4 m). Maximum Bi-Stacking Wall Width is 35'-5" (10.8 m).

# **CLEAR-DIVISIONS VARIOFOLD Product Specification**

# PART 1 - GENERAL SPECIFICATIONS

# 1.01 WORK INCLUDED

A. Moveable glass wall system shall be furnished, installed, and serviced by wall manufacturer's authorized distributor, in compliance with the architectural drawings and specifications contained herein.

#### 1.02 RELATED WORK

- A. Structural Support: Structural support system required for suspending the moveable glass wall shall be designed, installed, and pre-punched by others, in accordance with ASTM E 557 and manufacturer's shop drawings.
- B. Opening Preparation: Proper and complete preparation of the moveable glass wall system opening shall be by others in accordance with ASTM E 557, and shall include floor leveling; plumbness of adjoining permanent walls; substrate and / or ceiling tile enclosures for the track system; and the painting and finishing of trim and other materials adjoining the head and jamb areas of the moveable glass wall. Refer to a copy of the shop drawings for additional details.

#### 1.03 SYSTEM DESCRIPTION

- A. The moveable glass wall system shall consist of Continuously Hinged Panels that are manually operated, and top supported by one (1) carrier in every other panel with a bottom guide pin traveling in a recessed floor guide channel (flush with finished floor) providing lateral stability to the glass wall panels.
- B. The moveable glass wall system shall consist of nominal 3/8" [10] thick tempered glass panels suspended from a continuous aluminum glass retainer located at the top and bottom of each panel.

# 1.04 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is certified in writing by the moveable glass wall manufacturer as qualified to install the manufacturer's systems for work similar in material, design, and extent to that indicated for this project.
- B. The moveable glass wall panel shall utilize clear tempered glass per ASTM C 1048-04.
- C. The moveable glass wall shall be installed by the manufacturer's authorized distributor in accordance with ASTM E 557.

# 1.05 REFERENCES

- A. ASTM C 1036-01: Standard Specification for Flat Glass.
- B. ASTM C 1048-04: Standard Specification for Heat Treated Flat Glass.
- C. ASTM E 557: Architectural Application and Installation of Operable Partitions.

# 1.06 SUBMITTALS

- A. Manufacturer shall provide written technical information and related detail drawings, which demonstrate that products comply with contract documents for each type of moveable glass wall system specified.
- B. Manufacturer shall provide detailed engineering drawings featuring track plan, panel elevation, horizontal and vertical details and beam punching template as required.
- C. Manufacturer shall provide written instructions specifying the proper operation and maintenance of the moveable glass wall system.
- D. Manufacturer shall provide a color selector demonstrating the manufacturer's selections of the specified hardware finish.

# 1.07 DELIVERY, STORAGE AND HANDLING

- A. Panels shall be shipped in a completely enclosed wooden crate with high-density polystyrene blocks positioned between each panel to protect glass and hardware during delivery, storage and handling.
- B. Panels shall be stored on edge and above the floor on cushioned blocking in a dry and ventilated area, protected from humidity and temperature extremes.

#### 1.08 SEQUENCING / SCHEDULING

- A. Beam Punching: Manufacturer shall provide beam punching template drawing detailing the anchor locations for the suspended track system for Drop Rod Mounting, as required for the fabrication and installation of structural overhead support by others.
- B. Track Installation: Scheduling of moveable glass wall track installation shall occur after structural overhead support has been properly and completely fabricated and installed by others.
- C. Panel Installation: Moveable glass wall panel installation shall occur after fixed wall substrate construction is properly and completely installed by others, as required to protect panels from ongoing adjacent construction.

#### 1.09 WARRANTY

A. Manufacturer shall warrant each moveable glass wall system and its hardware components to be free from defects in material and workmanship for a period of two (2) years from the date of delivery to the original purchaser, when installed by an authorized KWIK-WALL distributor. (Glass is specifically excluded from the warranty.)

# **PART 2 - PRODUCT SPECIFICATIONS**

#### 2.01 ACCEPTABLE MANUFACTURER

A. Moveable glass walls shall be CLEAR-DIVISIONS VARIOFOLD Continuously Hinged Panels as manufactured by KWIK-WALL Company.

#### 2.02 PANEL CONSTRUCTION

- A. Panel Dimensions: Standard panel dimension shall be a nominal 1 7/16" [36.5] thick.
- B. Horizontal Top and Bottom Rails: Top and bottom rails shall be continuous one-piece extrusion manufactured of structural grade aluminum as engineered by HAWA<sup>®</sup>. Rails shall utilize a cam lock feature to provide positive mechanical attachment to glass. (Passive friction type or adhesive applied rails shall not be allowed for safety reasons.) Horizontal top rail on each panel that does not contain a carrier shall include a stopper to prevent the glass wall panels from over-closing.
- C. Bottom Rail Locking System: Alternating bottom glass retainers shall contain (select):
  - Standard Operable Floor Lock: consisting of thumb turn located on one (1) side of the panel connected to a
    floor lock that engages a recessed spring loaded dust-proof strike (for openings of two (2) panels or less) or
    a floor guide channel (for openings greater than two (2) panels) to provide security when the moveable glass
    wall system is extended.
  - 2. Optional Keyed / Thumb Turn Lock: consisting of key operated cylinders on both sides or key operation on one (1) side and thumb turn operation on opposite side.
- D. Glass: Panels shall be glazed with 3/8" [10] tempered glass that is manufactured in accordance with ASTM C 1036-01, ASTM C 1048-04 and ANSI Z97.1. Glass finish shall be (select):
  - 1. Standard Clear: consisting of 3/8" [10] clear tempered glass.
  - 2. Optional Clear Satin Etched: consisting of 3/8" [10] translucent tempered glass.
  - 3. Optional Decorated or Patterned: consisting of 3/8" [10] tempered glass decorated or patterned as selected by designer.
  - 4. Optional Berman editions: consisting of 3/8" [10] textured tempered glass with repeating pattern every 27" [685.8]. Texture shall be (select):
    - a. esto: directional texture, multi-directional, random, horizontal forms across a lightly brushed background.
    - b. être: organic texture inspired by the natural markings found in granite.
    - c. ima: linear design with 1/8" [3.2] thick freehand lines every 1/2" [12.7] on a light être texture background.
    - d. aquí: organic texture with freehand vertical markings.
- E. Panel Weight: Maximum panel weight shall not exceed 176 lb. (80 kg) calculated at 7.4 lb. / ft.<sup>2</sup> (36 kg / m<sup>2</sup>).
- F. Hinges: Panel hinges shall be architectural grade, full leaf butt type, with a Dull Chrome finish.

# 2.03 OPERATION

- A. Operation shall be Continuously Hinged Panels that are top supported by one (1) carrier in every panel, and a bottom guide pin traveling in a recessed floor guide channel (flush with finished floor) providing lateral stability to the glass wall panels.
- B. Moveable glass wall panels shall be extended / retracted utilizing specific type pull handles strategically located on glass panels. (Refer to Part 2.05 "B. Pull Handle Finish".)

#### 2.04 STACK ARRANGEMENTS

- A. Stack Type: Panel storage configuration shall be Offset Stack, consisting of panels stacked to one (1) side of the wall's installed position.
- B. Stack Quantity: Panels shall be stored at (select):
  - 1. Standard One (1) End: on one (1) end of the wall run.

2. Optional Both Ends: on both ends of the wall run.

#### 2.05 FINISHES

- A. Hardware Finish: Panel hardware including horizontal rails shall be finished of (select):
  - 1. Standard Finish: Clear Anodized Brushed Aluminum.
  - 2. Optional Finish: Stainless Steel Satin Effect.
- B. Pull Handle Finish: Handle shall have a Stainless Steel Satin Effect finish.

#### 2.06 PERIMETER TRIM AND SEALS

- A. Trim and Seals shall consist of (select):
  - 1. Standard Trimless: consisting of 3/8" [10] tempered glass with a sanded / beveled edge, resulting in a minimal groove appearance between adjacent glass panels.
  - 2. Optional Horizontal Top and Bottom Brush Seals: consisting of continuous contact black nylon brush seals provided on both sides of each panel.

# 2.07 CLOSURE SYSTEMS

- A. Initial Closure System: The lead panel (the first panel exiting the stack) shall intersect vertically against a rigid wall surface or Fixed Pivot or Fixed Swing Panel, as accomplished by a lead panel that does not use any vertical jamb to affect initial closure, and shall contain a pull handle on both sides. (Refer to Part 2.05 "B. Pull Handle Finish".)
- B. Final Closure System: The final closure panel (the last panel at the stack end) shall provide a method for affecting final closure of the moveable glass wall system. The type of final closure panel shall be (select):
  - 1. Standard Fixed Pivot Panel Closure (even or odd number of panels): consisting of a panel utilizing top and bottom pivots allowing the panel to pivot and be used to affect final closure. Final closure panel shall contain a pull handle. (Refer to Part 2.05 "B. Pull Handle Finish".)
  - 2. Optional Fixed Swing Panel Closure (odd number of panels only): consisting of a lead panel utilizing a top pivot and bottom pivot that engages with a self-closing unit containing a hold-open feature that is recessed flush into the floor allowing the panel to pivot 90° in both directions and providing access thru the moveable glass wall system when it is setup in the extended position. Both sides of the Fixed Swing Panel shall contain a pull handle. (Refer to Part 2.05 "B. Pull Handle Finish".)

(Note: If optional Fixed Swing Panel is selected, panel must be located at the end opposite the stack area.)

# 2.08 PANEL ACCESSORY

A. Floor Guide Channel: Consisting of a clear anodized extruded aluminum channel that is recessed into the floor (flush with finished floor) to provide additional stability to panels as they are moved in and out of their storage location. Channel shall be compatible with bottom guide pin located at bottom of panels and shall be furnished by the moveable glass wall manufacturer as noted on submitted shop drawings. (Optional on openings of two (2) panels or less. Standard on openings greater than two (2) panels.)

# 2.09 TRACK SYSTEM

A. Aluminum Track: The VARIOFOLD track system shall be extruded of structural grade aluminum alloy, as engineered by HAWA<sup>®</sup>, and finished in anodized clear satin finish, which resists color fading and flaking. Track shall be reinforced overhead by heavy-duty steel Drop Rod Brackets. Each Drop Rod Bracket shall have a pair of steel all-rods extending to the overhead structural support.

# 2.10 CARRIER SYSTEM

A. Carrier: Every other panel shall be top supported by one (1) carrier utilizing a 3/8" [10] diameter pendant bolt. Each carrier shall consist of four (4) permanently-lubricated, ball bearing steel wheels with high-density polymer tires as required for ease of panel movement.

# 2.11 SUSPENSION SYSTEMS

- A. Mounting Systems: The VARIOFOLD track system shall be supported by (select):
  - 1. Standard Drop Rod Bracket Mount: consisting of steel drop rod brackets with drop rods, consisting of adjustable rods of grade 2, 3/8" [10] diameter threaded steel all-rod provided with 3/8" [10] serrated steel nuts.

2. Optional Direct Mount: consists of #16 x 3" [76] wood screws for attachment to a level overhead structural (wood) support.

# **PART 3 - EXECUTION**

#### 3.01 INSPECTION

- A. Proper and complete preparation of the moveable glass wall system opening shall be by others in accordance with the architectural drawings, manufacturer's shop drawings and ASTM E 557. Any deviation of the actual opening from these specifications shall be called to the attention of the architect prior to the installation of the moveable glass wall system.
- B. Deficiencies in the moveable glass wall opening shall be corrected by others prior to installation of the moveable glass wall system.

# 3.02 INSTALLATION

- A. The moveable glass wall system shall be installed by manufacturer's authorized distributor.
- B. The moveable glass wall shall be installed in accordance with manufacturer's written instructions, shop drawings and ASTM E 557 installation guidelines.

# 3.03 ADJUSTING AND CLEANING

A. The moveable glass wall panels and track system shall be adjusted and cleaned in accordance with manufacturer's written instructions.

#### 3.04 PROTECTION

A. The moveable glass wall panels shall be stored in the stacked (retracted) position prior to acceptance by the owner's representative.

#### 3.05 DEMONSTRATION

A. The moveable glass wall manufacturer's authorized distributor shall demonstrate proper operation and explain proper and necessary maintenance requirements of the moveable glass wall system to the owner's representative.

#### For additional information contact:

KWIK-WALL Company 1010 East Edwards Street Springfield, Illinois 62703

Phone: 217-522-5553 or 800-280-5945 (United States and Canada only) Fax: 217-522-1170 or 800-290-5945 (United States and Canada only)

Website: www.kwik-wall.com Email: kwinfo@kwik-wall.com

Note:

Due to ongoing research and development, some variations may occur in product specifications.